

Distributed by:



S.I.A.T.A Asia Pacific Pte Ltd

37 Tannery Lane  
#06-08 Tannery House  
Singapore 347790  
Tel: +65 6741 2994 • Fax: +65 6741 2995

[www.siata.com.sg](http://www.siata.com.sg)

### PRODUCT DATA SHEET


*This is a typical analysis of material produced and does not constitute a product certification for material supply.*

**Product:** W2 (20-40mm NOM  $\pm 8\%$ )

**Appearance:** Gravel

**Main Applications:** Filtration Medium

**Indicative Grading Analysis:** Sieve Standards: ASTM C136, AS1141.11.1, AWS App B  
Sampling Methods: ASTM D75, AS1141.3.1



Aperture (mm)	45.0	37.5	28.5	22.4	18.0	Pan
Cum. % Passing	100	87	26	8	1	0
% Retained	0	13	61	18	7	1

*Note: Indicative grading only. Grading analysis will vary slightly over time due to changes in raw feed.*

#### Other Properties

Moisture Content  
Bulk Density  
Acid Solubility  
Material <75 $\mu$ m  
Specific Gravity

#### Limits

<5%  
Approx. 1.5 t/m<sup>3</sup>  
<1%  
<1%  
>2.5

#### Test Methods

AS 1289.2.1.1, BEWA 18.93  
AS 1141.4 AWS App D  
AWWA-B100 (50% HCl)  
ASTM C117, AS 1141.12  
ASTM C188, AS 1141.5

This product may contain metallic impurities. Please review suitability of this product prior to use.

River Sands operates and maintains a certified quality system in accordance with AS/NZS ISO 9001:2008.

The quality system is third party certified by BCI/NCSI

River Sands also maintains a registered NATA laboratory

Registration #6898

Registration #10470