

Distributed by:



S.I.A.T.A Asia Pacific Pte Ltd


37 Tannery Lane
#06-08 Tannery House
Singapore 347790
Tel: +65 6741 2994 • Fax: +65 6741 2995

www.siata.com.sg

PRODUCT DATA SHEET

This is a typical analysis of material produced and does not constitute a product certification for material supply.

Product: 7S(ES: 0.55-0.65mm UC \leq 1.35)
Appearance: Dry sand, graded to the above specification
Main Applications: Filtration Medium
Indicative Grading Analysis: Sieve Standards: ASTM C136, AS1141.11, AWS App B
Sampling Methods: ASTM D75, AS1141.3.1



Aperture (mm)	1.40	1.18	1.00	0.85	0.710	0.60	0.50	0.00
Cum. % Passing	100	99	88	65	38	7	1	0
% Retained	0	1	13	21	27	31	6	1

Note: Indicative grading only. Grading analysis will vary slightly over time due to changes in raw feed.

Other Properties

Moisture Content
Bulk Density
Acid Solubility
Material <75 μ m
Specific Gravity

Limits

<1%
Approx. 1.5 t/m³
<1%
<1%
>2.5

Test Methods

AS 1289.2.1.1
AS 1141.4 AWS App D
AWWA-B100 (50% HCl)
ASTM C117, AS 1141.2
ASTM C128, AS 1141.5

This product may contain metallic impurities. Please review suitability of this product prior to use.

River Sands operates and maintains a certified quality system in accordance with AS/NZS ISO 9001:2008.

The quality system is third party certified by BCI/NCSI

River Sands also maintains a registered NATA laboratory

Registration #6898

Registration #10470